



Fire Crest Fire Protection Ltd.  
 The Wilson Building  
 Wilson Way  
 Pool, Redruth  
 Cornwall  
 TR15 3RU  
 Tel.: 0800 092 40 21  
 alarms@extinguisher.com

**General notes and fire drill instructions on the CB 200 Fire Alarm Control panel with re-settable call points.**

**EMERGENCY CALL OUT MOBILE NUMBER.  
 TO PHONE OR TEXT THE ENGINEER 24 / 7  
 077 924 688 99**



1 Silence Alarm  
 2 Reset System  
 3 Evacuate  
 4 Engineering only  
 5 Engineering only

**Enable controls by access code 514**

Fire drill or weekly call point activation can be achieved by activating the call point or by pressing the evacuate button on the control panel.

Activation of the call point can be achieved by pressing the front button Fig 2 **A** symbol, causing the flexible front Perspex to latch in. The two-prong reset tool Fig 2 Item **B** when inserted into the underside of the call point will click the Perspex back into position. **The alarm will continue to sound** (latched on) the alarm panel must be reset by pressing the **access code 514** on the numbered buttons then **silence alarm** (button 1) followed by (button 2) **Reset system**.

Fire Drill can also be achieved by entering the access code 514 then pressing button 3 evacuate. Stop the alarm sound by pressing button 3 evacuate again.

**Resetting after a false alarm.**

False alarms are very rare, should the panel be activated it is **IMPORTANT** to note the reason. Either the general fault or zone location LED will show. If the zone location LED is illuminated, completely check the zone area for a fire before resetting the system. The activating sensor will have an illuminated red LED on the side, make a note of this. Enter the event into the logbook. Call 08700 110 470 should you experience repeated false alarms.

Make yourself aware of the full operating instructions supplied with the panel and with the logbook action list. Remember a fire alarm is a piece of **“life saving equipment”** ownership implies a legal responsibility, with a **DUTY** of **CARE**.

Be aware of the evacuation procedure and emergency contact numbers.



**A**

Fig 2

User re-settable call point

**B**



Please note, other buildings may have different types of call points. Commonly, glass or breakable Perspex inserts have been used. These will actually 'break' if activated, needing a replacement glass. In this case a test key should be used for fire drill activation.

**Establish a 'mind set' culture of health and safety.  
 Keep the logbooks up to date.**

Emergency call out line is subject to Orange mobile network availability, please leave a message or text we will respond as soon as possible. For on site visits, a call out charge will apply at contracted rates.