




Fire Crest Fire Protection  
 The Wilson Building  
 Wilson Way  
 Pool, Redruth  
 Cornwall  
 TR15 3RU  
 Tel 0800 092 40 21  
 Fax 0845 527 63 73  
 alarms@extinguisher.com

## Enabling the Controls

**If the amber shift LED is lit then ignore 1)**

- 1) PRESS BUTTON 2 TO ENABLE THE DISPLAY
- 2) ENTER ACCESS CODE 2 2 2
- 3) The amber SHIFT LED will now be lit.



You are now in ACCESS LEVEL TWO and may proceed to silence and reset the system.

### Silence Alarms

When the fire procedures have been carried out and it is safe to silence the alarm, proceed as follows:

To silence the alarms press the [ALARMS ON/OFF] button

### Reset System

**Before attempting to reset the system the cause of the alarm should be established.**



To reset the system press the [RESET SYSTEM] button.

**Note: if the alarm condition still exists, e.g. a broken glass in a break glass unit or smoke not cleared then the panel will revert to the fire state until the cause for the alarm is removed.**

### Sound Alarms

To sound the alarms at any time after they have been silenced, proceed as follows:

To sound the alarms press the [ALARMS ON/OFF] button at ACCESS LEVEL 2 as above.

### Silence Buzzer

To silence the buzzer press the [SILENCE BUZZER] button at (this function is also available at access level 1 if required, so no code need be entered).

Note: if the panel does not reset or a fault condition is displayed, call your maintenance engineer immediately.

### Log Book

Remember to update your log book with the suspected cause of the alarm. This will help your maintenance engineer to investigate and suggest modifications or improvements

**24/7 Engineers Call Out Number  
07792 468 899**

◆ Fire Alarm Installs ◆ Fire Alarm Service ◆ Emergency Lighting ◆ Extinguishers ◆ Training ◆